

Office of the District Fire Officer  
Karnataka State Fire  
and Emergency Services  
Khanapur Road, Belagavi -590001



Phone : 0831-2429441  
E-Mail : dfobgv@gmail.com

C.NO/113/FSCR/DFO/BELAGAVI/2025

Date : 28-06-2025

To,  
The Principal,  
Joshi's Central Public School  
Joshi Nagar, Mandoli Road, Tilakwadi,  
Belagavi, Belagavi Taluk & District.

Sir,

Sub:- Issue of "Fire Safety Compliance Report" to Joshi's Central Public School, Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District.

Ref:- 1) C.NO/113/FSR/DFO/BELAGAVI/2025 Date: 27-06-2025.

2) C.No/36/FSO/Belagavi/2025 Date: 28-06-2025.

\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*

With reference to the subject above cited, the premises of Joshi's Central Public School, building consisting with Basement, Ground & 1 Upper floors situated at Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District was inspected by Fire Station Officer Belagavi on 28-06-2025 with respect to fire Prevention, Fire Fighting & Evacuation point of view for the purpose of issuing Fire Safety Compliance Report and has submitted the details as under.

#### ANNEXURE-1

(Up to 14.99 mtrs. In height)

#### "GROUP-B Educational Buildings

*NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.*

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

#### A. Details of the Building/Premises.

01	Name and Address of the Applicant	The Principal, Joshi's Central Public School Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District.
02	Name and Address of the Premises	Joshi's Central Public School Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District.
03.	Name and Address of the Building Owner	The President Joshi's Central Public School Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District.
04.	Number of Building	01
05.	Number of Floors	Basement, Ground & One Upper Floor
06.	Floor-wise details of Occupancy:-	
	Basement	Parking
	Ground Floor	Office-01, Sports Room-01, Computer/Library-01, Class Room-7 & Electrical Room-01.
	1 <sup>st</sup> floor	Class Room-06
07.	Height of the building	06.70 Mtr
08.	Site area	1346.69 Sq Mtr
09.	Built-up area of each floor:-	

	Basement	506.00 Sq Mtr
	Ground Floor	614.13 Sq Mtr
	1 <sup>st</sup> floor	345.89 Sq Mtr
10.	Total Built-up area	1466.02 Sq Mtr
11.	<b>Surrounding properties:-</b>	
	East	Residential Building
	West	Private Property
	North	Private Property
	South	Road
12.	<b>Open Space all around the building</b>	
	East	04.25 Mtr
	West	01.86 Mtr
	North	0.95 Mtr
	South	Nil
<b>Allowed Setbacks ( open space) should be maintained free from further obstruction/construction.</b>		

**B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-**

Sl. No (01)	Details (02)	Existing (03)		Recommendations (04)	
01.	Accessibility to the premises	The premises is accessible from 07.50 mtr wide road on the Southern side.		Adequate	
02.	Number of Entrances	02 Nos, One of 03.20 Mtr on southern side & another one of 1.75 mtr on Northern side		Adequate	
03.	Number of Staircase	No of staircase	02 Nos		Complied
		Width of the staircase	01.50 Mtr	01.50 Mtr	
		Width of threads	0.28 Mtr	0.25 Mtr	
		Height of risers	0.17 Mtr	0.17 Mtr	
		No of risers per flight	11	07	
		Height of the hand drill.	--	--	
04.	Portable Extinguishers	03 nos. of 6 Kg capacity ABC type & 01 no. of 4.5 Kg capacity CO2 type extinguisher has been provided.  All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.		Complied	
05.	Hose reel hose system	02 Nos. of Hose reel Hose has been provided. The hose reel hose of min 19 mm size and of 30 mtrs length has been		Complied	

		provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size.	
	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup>	The system has been connected to booster pump of 450 LPM capacity. Further the system also has been connected to alternative source of power supply.	Complied
07.	Diesel Generator	15 KVA generator has been provided.	Complied.
08.	Terrace Tank	7000 Ltrs Capacity Overhead Tank has been Provided.	Complied
09.	Escape routes	Direction in which the students/teachers have to move in the event of emergency has been indicated in the corridor/passage as a guide during evacuation.	Complied.
10.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency has been displayed along with the telephone numbers of Belagavi Fire station i.e 0831-2429441, 101 & 080-22971550, 22971500, 22971600 the telephone no's nearest ambulance services and police station.	Complied
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit.	Complied
12.	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.	Complied
13.	Nominate One Fire Nodal Officer	Smt. Rekha Malkannavar & Sri. Appaji Maste are nominated as fire nodal officer	Complied
14.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.


15. **Fire Precautionary Measures**

- A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.
- B:- Accumulation of combustibile waste in and around the premises should be avoided.
- C:- The Exit ways shall be always kept clear without any obstruction.
- D:- Liquefied petroleum gas should not be stored in the building.
- E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.
- F:- During the class hours the class room door shall not be locked from inside to out side.
- G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordination with the fire services department.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "**Fire Safety Compliance Report**" to Joshi's Central Public School, Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District. As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "**Fire Safety Compliance Report**" is valid for only one year from the date of issue and is renewable.

Yours Faithfully

  
District Fire Officer  
Karnataka State Fire And Emergency Services  
Belagavi-01.

Copy to,  
Fire Station Officer, Belagavi

Office of the District Fire Officer  
Karnataka State Fire  
and Emergency Services  
Khanapur Road, Belagavi-590001



Phone : 0831-2429441  
E-Mail : dfobgv@gmail.com

C.NO/113/FSCR/DFO/BELAGAVI/2025

Date : 28-06-2025

To,  
The Principal,  
Joshi's Central Public School  
Joshi Nagar, Mandoli Road, Tilakwadi,  
Belagavi, Belagavi Taluk & District.

Sir,

Sub:- Issue of "Fire Safety Compliance Report" to Joshi's Central Public School, Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District.

Ref:- 1) C.NO/113/FSR/DFO/BELAGAVI/2025 Date: 27-06-2025.  
2) C.No/36/FSO/Belagavi/2025 Date: 28-06-2025.

\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*

With reference to the subject above cited, the premises of Joshi's Central Public School, building consisting with Basement, Ground & 1 Upper floors situated at Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District was inspected by Fire Station Officer Belagavi on 28-06-2025 with respect to fire Prevention, Fire Fighting & Evacuation point of view for the purpose of issuing Fire Safety Compliance Report and has submitted the details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height)

"GROUP-B Educational Buildings

*NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.*

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01.	Name and Address of the Applicant	The Principal, Joshi's Central Public School Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District.
02.	Name and Address of the Premises	Joshi's Central Public School Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District.
03.	Name and Address of the Building Owner	The President Joshi's Central Public School Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District.
04.	Number of Building	01
05.	Number of Floors	Basement, Ground & One Upper Floor
06.	Floor-wise details of Occupancy:-	
	Basement	Parking
	Ground Floor	Office-01, Sports Room-01, Computer/Library-01, Class Room-7 & Electrical Room-01.
	1 <sup>st</sup> floor	Class Room-06
07.	Height of the building	06.70 Mtr
08.	Site area	1346.69 Sq Mtr
09.	Built-up area of each floor:-	



	Basement	506.00 Sq Mtr
	Ground Floor	614.13 Sq Mtr
	1 <sup>st</sup> floor	345.89 Sq Mtr
10.	Total Built-up area	1466.02 Sq Mtr
11.	Surrounding properties:-	
	East	Residential Building
	West	Private Property
	North	Private Property
	South	Road
12.	Open Space all around the building	
	East	04.25 Mtr
	West	01.86 Mtr
	North	0.95 Mtr
	South	Nil
Allowed Setbacks ( open space) should be maintained free from further obstruction/construction.		

B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

Sl. No (01)	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from 07.50 mtr wide road on the Southern side.		Adequate
02.	Number of Entrances	02 Nos, One of 03.20 Mtr on southern side & another one of 1.75 mtr on Northern side		Adequate
03.	Number of Staircase	No of staircase	02 Nos	Complied
		Width of the staircase	01.50 Mtr      01.50 Mtr	
		Width of threads	0.28 Mtr      0.25 Mtr	
		Height of risers	0.17 Mtr      0.17 Mtr	
		No of risers per flight	11              07	
		Height of the hand drill.	--              --	
04.	Portable Extinguishers	03 nos. of 6 Kg capacity ABC type & 01 no. of 4.5 Kg capacity CO2 type extinguisher has been provided.  All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.		Complied
05.	Hose reel hose system	02 Nos. of Hose reel Hose has been provided. The hose reel hose of min 19 mm size and of 30 mtrs length has been		Complied



		provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size.	
	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup>	The system has been connected to booster pump of 450 LPM capacity. Further the system also has been connected to alternative source of power supply.	Complied
07.	Diesel Generator	15 KVA generator has been provided.	Complied.
08.	Terrace Tank	7000 Ltrs Capacity Overhead Tank has been Provided.	Complied
09.	Escape routes	Direction in which the students/teachers have to move in the event of emergency has been indicated in the corridor/passage as a guide during evacuation.	Complied.
10.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency has been displayed along with the telephone numbers of Belagavi Fire station i.e 0831-2429441, 101 & 080-22971550, 22971500, 22971600 the telephone no's nearest ambulance services and police station.	Complied
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit.	Complied
12.	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.	Complied
13.	Nominate One Fire Nodal Officer	Smt. Rekha Malkannavar & Sri. Appaji Maste are nominated as fire nodal officer	Complied
14.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.



15.


**Fire Precautionary Measures**

- A:- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sub panel premises.  
B:- Accumulation of combustible waste in and around the premises should be avoided.  
C:- The Exit ways shall be always kept clear without any obstruction.  
D:- Liquefied petroleum gas should not be stored in the building.  
E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.  
F:- During the class hours the class room door shall not be locked from inside to outside.  
G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordination with the fire services department.


Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Compliance Report" to Joshi's Central Public School, Joshi Nagar, Mandoli Road, Tilakwadi, Belagavi, Belagavi Taluk & District. As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "Fire Safety Compliance Report" is valid for only one year from the date of issue and is renewable.

Yours Faithfully

  
District Fire Officer  
Karnataka State Fire And Emergency Services  
Belagavi-01.

Copy to,  
Fire Station Officer, Belagavi

  
Principal  
Joshi's Central Public School  
Belagavi

